

DISTRICT PUBLIC HEALTH LAB

DISTRICT CIVIL HOSPITAL, GURUGRAM

D.No. 159/Mic/2026

Dated...1/1/26.....

To

The S.M.O./M.O. Incharge,

CHC/PHC.....PHC Kasan.....

SUB : WATER SAMPLES REPORT

In reference to your letter No. 149/- 29/5/26.....

Dated...29/5/26..... vide which you have sent water samples for bacteriological examination, the result of each is as under :

Sr. No.	Place of Collection	Result	PCC
1.	Deepika Public School (Manesar)	Fit	2/100 ml Class - 2nd
2.			
3.			
4.			
5.			

P.C.C. Presumptive coliforms count

* Above samples are tested by multiple tube methods.

INTERPRETATION

PCC Per 100ml	CLASS	REMARK	RESULT
0	I	EXCELLENT	FIT
1 - 3	II	SATISFACTORY	FIT
4 - 9	III	SUSPICIOUS	UNFIT
> 9	IV	UN SATISFACTORY	UNFIT

* The Result given above are related to samples as received & tested in Lab..

Dr. Monika Yadav
MD, Microbiology
Medical Officer

(MICROBIOLOGIST)
D.C.H., Gurugram